

【八代北部浄化センター】放流水 分析結果一覧

令和7年度（2025年度）

項 目		排水 基準値	単位	4月		5月		6月		7月		8月		9月		10月		11月		12月		1月		2月		3月		平均値	最大値	最小値
				4/3	4/17	5/8	5/22	6/5	6/19	7/3	7/17	8/7	8/21																	
健	1 カドミウム	0.03	mg/l	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003															<0.003	<0.003	<0.003
	2 シアン	1	mg/l	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															<0.1	<0.1	<0.1
	3 有機りん	1	mg/l	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															<0.1	<0.1	<0.1
	4 鉛	0.1	mg/l	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005															<0.005	<0.005	<0.005
	5 六価クロム	0.2	mg/l	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002															<0.002	<0.002	<0.002
	6 ヒ素	0.1	mg/l	0.002	0.002	0.002	0.001	0.002	<0.001	0.001	0.001	0.002	0.002															0.002	0.002	<0.001
	7 総水銀	0.005	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005															<0.0005	<0.0005	<0.0005
	8 アルキル水銀	不検出	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005															<0.0005	<0.0005	<0.0005
	9 P C B	0.003	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005															<0.0005	<0.0005	<0.0005
	10 ジクロロメタン	0.2	mg/l	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002															<0.002	<0.002	<0.002
康	11 四塩化炭素	0.02	mg/l	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002															<0.002	<0.002	<0.002
	12 1,2-ジクロロエタン	0.04	mg/l	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004															<0.004	<0.004	<0.004
	13 1,1-ジクロロエチレン	1	mg/l	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01															<0.01	<0.01	<0.01
	14 シス-1,2-ジクロロエチレン	0.4	mg/l	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004	<0.004															<0.004	<0.004	<0.004
	15 1,1,1-トリクロロエタン	3	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005															<0.0005	<0.0005	<0.0005
	16 1,1,2-トリクロロエタン	0.06	mg/l	<0.006	<0.006	<0.006	<0.006	<0.006	<0.006	<0.006	<0.006	<0.006	<0.006															<0.006	<0.006	<0.006
	17 トリクロロエチレン	0.1	mg/l	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002															<0.002	<0.002	<0.002
	18 テトラクロロエチレン	0.1	mg/l	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005	<0.0005															<0.0005	<0.0005	<0.0005
	19 1,3-ジクロロプロパン	0.02	mg/l	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002	<0.0002															<0.0002	<0.0002	<0.0002
	20 チウラム	0.06	mg/l	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006	<0.0006															<0.0006	<0.0006	<0.0006
項	21 シマジン	0.03	mg/l	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003	<0.003															<0.003	<0.003	<0.003
	22 チオベンカルブ	0.2	mg/l	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002	<0.002															<0.002	<0.002	<0.002
	23 ベンゼン	0.1	mg/l	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001															<0.001	<0.001	<0.001
	24 セレン	0.1	mg/l	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001															<0.001	<0.001	<0.001
	25 ホウ素	10	mg/l	0.1	<0.1	0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															0.1	0.1	<0.1
	26 フッ素	8	mg/l	0.1	<0.1	<0.1	0.1	<0.1	0.1	<0.1	0.1	0.1	<0.1	<0.1														0.1	0.1	<0.1
	27 1,4-ジオキシン	0.5	mg/l	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005	<0.005															<0.005	<0.005	<0.005
	28 NH4-N、NO2-N、NO3-N	100	mg/l	5.8	5.6	5.6	3.6	5.8	5.1	7.2	4.9	5.3	5.4															5.4	7.2	3.6
	1 pH	5.8～8.6	—	6.7	7.2	7.4	6.7	6.9	6.7	7.5	6.7	7.0	6.9															7.0	7.5	6.7
生	2 BOD	20	mg/l	1.1	1.1	0.9	1.2	0.9	0.8	0.8	1.3	1.1	1.6															1.1	1.6	0.8
	3 COD	20	mg/l	7.8	6.6	6.1	5.3	6.2	5.8	5.7	6.0	7.1	6.3															6.3	7.8	5.3
	4 SS	70	mg/l	1	1	1	1	2	2	<1	1	1	1															1	2	<1
	5 大腸菌数	800	CFU/ml	0	0	0	0	0	0	0	0	0	0															0	0	0
	6 T-N	120	mg/l	6.8	6.3	5.9	3.8	6.9	5.7	7.9	5.7	6.3	6.5															6.2	7.9	3.8
	7 T-P	16	mg/l	0.8	1.4	1.0	0.5	1.2	0.2	1.7	0.9	0.8	1.7															1.0	1.7	0.2
	8 鉱油類	5	mg/l	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5															<0.5	<0.5	<0.5
	9 動植物油脂類	30	mg/l	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5	<0.5															<0.5	<0.5	<0.5
	10 フェノール類	5	mg/l	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															<0.1	<0.1	<0.1
	11 銅	3	mg/l	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02															<0.02	<0.02	<0.02
目	12 亜鉛	2	mg/l	0.03	0.04	0.03	0.02	0.06	0.03	0.03	0.03	0.03	0.03															0.03	0.06	0.02
	13 溶解性鉄	10	mg/l	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															<0.1	<0.1	<0.1
	14 溶解性マンガン	10	mg/l	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1	<0.1															<0.1	<0.1	<0.1
	15 全クロム	2	mg/l	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04	<0.04															<0.04	<0.04	<0.04

注：排水基準値は水質汚濁防止法に基づく排水基準値